



ALL WIRING BETWEEN METER BASE AND DISC. MUST BE INSIDE CONDUIT.

Meter Base To be No Smaller Than 200 AMPS

DISTANCE FROM METER BASE TO MAIN DISCONNECT MUST NOT EXCEED 36\"(IN.)

MAIN DISC. & MULTI-BREAKER SHALL BE INSTALLED EITHER INSIDE OR OUTSIDE OF A BUILDING OR STRUCTURE AT A READILY ACCESSIBLE LOCATION NEAREST THE POINT OF ENTRANCE OF THE SERVICE CONDUCTORS.

* CUSTOMER GROUNDING SHALL BE IN ACCORDANCE WITH THE CURRENT ADDITION OF THE NATIONAL ELECTRICAL CODE

BECI ENGINEERING MAPPING H:\DeanJ\AUTOCAD\Dwgs\SPECs\Diagrams\ PERMANENT RESIDENTIAL UG.dwg DATE: FEB 26, 2018 TIME: 7:52 AM

PERMANENT RESIDENTIAL UNDERGROUND SOURCE

BEAUREGARD ELECTRIC COOPERATIVE INC.
DERIDDER, LOUISIANA 70634

- *NOTIFY CITY, MUNICIPAL, OR PARISH FOR ANY CODES, PERMITS OR REQUIREMENTS APPLICABLE.
- *FACILITIES SHALL COMPLY WITH NATIONAL ELECTRIC CODE (NEC)
- *LA-1 CALL 1-800-272-3020 PLEASE CALL BEFORE DIGGING
- *A BECI LINEMAN MUST MEASURE FOR THE WIRE AND MUST INSPECT THE TRENCH BEFORE COVERING
- *BECI WILL INSTALL CONDUIT AND BRACKETS ON POLE

NO.	DATE	BY	REVISION
2	2/26/18	DJ	REVISION
1	1/14/16	DJ	REVISION